



Date Submitted: 1/17/2019

Water Use Efficiency Annual Performance Report - 2018

WS Name: CAMANO WATER ASSOCIATION

Water System ID# : 10750

WS County: ISLAND

Report submitted by: *Peter Turner*

Meter Installation Information:

Estimate the percentage of metered connections: *100%*

If not fully metered - Current status of meter installation:

Production, Authorized Consumption, and Distribution System Leakage Information:

12-Month WUE Reporting Period: *01/01/2018* To *12/31/2018*

Incomplete or missing data for the year? *No*

If yes, explain:

Distribution System Leakage Summary:

Total Water Produced and Purchased (TP) – Annual Volume	58,536,649 gallons
Authorized Consumption (AC) – Annual Volume	54,734,031 gallons
Distribution System Leakage – Annual Volume TP – AC	3,802,618 gallons
Distribution System Leakage – Percent DSL = $[(TP - AC) / TP] \times 100$	6.5 %
3-year annual average	6.4 %

Goal-Setting Information:

Date of Most Recent Public Forum: *05/20/2014* Has goal been changed since last performance report? *No*

Note: Customer goal must be re-established every 6 years through a public process

WUE Goals:

Customer Goal (Demand Side):

To reduce the single family sales by an average of 5% per year for the next five yaers.

Describe Progress in Reaching Goals:

Customer (Demand Side) Goal Progress:

In 2014 CWA started to charge it's customers for every gallon of water consumed. CWA aims to reduce consumption by 20% over the next few years. CWA has installed new meters at it's well heads and at the treatment plane. CWA has seen a 22.5% decrease in it's water consumption since 2009.

Additional Information Regarding Supply and Demand Side WUE Efforts

Include any other information that describes how you and your customers use water efficiently:

In its continuing efforts to conserve water CWA began a project in 20013 to systematically replace old pipes throughout its service area, since the project began CWA has replaced 5,400 LF of old pipe with new 6"HDPE pipe. In October 2018 CWA started to replace another 5,100 feet of old pipe, this project will finish at the end of February 2019.

Do not mail, fax, or email this report to DOH